

EXHIBIT "F"

ATTACHED



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, Florida 33902-2549

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:

City of Marathon

PERMIT NUMBER:

FLA550973

PA FILE NUMBER:

FLA550973-001-DW2P

ISSUANCE DATE:

September 11, 2007

EXPIRATION DATE:

September 10, 2011

RESPONSIBLE AUTHORITY:

Mr. Michael Puto
City Manager
10045-55 Overseas Highway
Marathon, FL 33050

(305) 289-4130

FACILITY:

City of Marathon Area 4 WWTP
Behind 5601 Overseas Highway
Marathon, FL 33050
Monroe County
Latitude: 24° 42' 57" N Longitude: 81° 04' 21" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). The above named permittee is hereby authorized to construct and operate the facilities shown on the application and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

TREATMENT FACILITIES:

The facility is a new advanced domestic wastewater treatment plant with a permitted capacity of 0.400 million gallons per day (MGD) annual average daily flow (AADF). The facility is a sequencing batch reactor consisting of influent screening, aeration, chemical feed, filtration, final sedimentation, chlorination, and denitrification. Its circular main unit has three 210,000 gallon batch tanks, one 67,000 gallon covered effluent equalization tank, and one 188,000 gallon aerobic digester.

Filtration and disinfection occurs in two identical units. Each unit has a filter surface area of 72 square feet, an 11,500 gallon chlorine contact chamber, and a 5,530 gallon mudwell. Disinfection is met using sodium hypochlorite.

DISPOSAL:

Underground Injection: A new 0.400 MGD AADF permitted capacity injection well system (U-001) consisting of 2 Class V, Group 3 injection wells permitted under Department permit number(s) 272717-001 and-002 UC discharging to Class G-III ground water. U-001 is located onsite approximately at latitude 24 ° 42' 57" N, longitude 81 ° 04' 21" W.

REUSE:

Land Application: A new 0.400 MGD AADF permitted capacity slow-rate public access (R-001) consisting of an area that has a reuse capacity of 1.134 MGD.

IN ACCORDANCE WITH: The limitations, monitoring requirements and other conditions set forth in Pages 1 through 24 of this permit.

FACILITY: City of Marathon Area 4 WWTP
 PERMITTEE: City of Marathon
 10045-55 Overseas Highway
 Marathon, FL 33050

PERMIT NUMBER: FLA550973
 PA FILE NUMBER: FLA550973-001-DW2P/NP

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Underground Injection Control Systems

1. During the period beginning upon placing the new facilities into operation and lasting through the expiration date of this permit, the permittee is authorized to discharge effluent to Injection Well Facility U-001 located onsite. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.10:

Monitoring Requirements										
			Effluent Limitations							
Parameter	Units	Max/Min	Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow	MGD	Maximum	0.400	-	-	-	5 Days/Week	Calculated	CAL-03	
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	5.0	6.25	7.5	10.0	Every Two Weeks	8-hour flow proportioned composite	EFF-01	
Solids, Total Suspended	MG/L	Maximum	5.0	6.25	7.5	10.0	Every Two Weeks	8-hour flow proportioned composite	EFF-01	
pH	SU	Range	-	-	-	6.0 to 8.5	5 Days/Week	Grab	EFA-01	
Coliform, Fecal	See Permit Condition I.A.3.									
Total Residual Chlorine (For Disinfection)	MG/L	Minimum	-	-	-	0.5	5 Days/Week	Grab	EFA-01	See Cond I.A.4
Nitrogen, Total (as N)	MG/L	Maximum	3.0	3.75	4.5	6.0	Every Two Weeks	8-hour flow proportioned composite	EFF-01	
Phosphorus, Total (as P)	MG/L	Maximum	1.0	1.25	1.5	2.0	Every Two Weeks	8-hour flow proportioned composite	EFF-01	

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

2. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I. A. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
CAL-03	Flow to the wells is calculated by subtracting the value of the flow to the reuse system (CAL-02) from the value of the influent flow (FLW-01).
EFA-01	At the exit end of the chlorine contact chambers just prior to discharge.
EFF-01	Composite sampler on chlorine contact chambers' discharge line.

3. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed 200 per 100 mL of effluent sample. The geometric mean of the fecal coliform values for a minimum of 10 samples of effluent each collected on a separate day during a period of 30 consecutive days (monthly), shall not exceed 200 per 100 mL of sample. No more than 10 percent of the samples collected (the 90th percentile value) during a period of 30 consecutive days shall exceed 400 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 800 fecal coliform values per 100 mL of sample. Note: To report the 90th percentile value, list the fecal coliform values obtained during the month in ascending order. Report the value of the sample that corresponds to the 90th percentile (multiply the number of samples by 0.9). For example, for 30 samples, report the corresponding fecal coliform number for the 27th value of ascending order. [62-600.440(4)(c)]
4. A minimum of 0.5 mg/L total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-600.440(4)(b)]

FACILITY: City of Marathon Area 4 WWTP
 PERMITTEE: City of Marathon
 10045-55 Overseas Highway
 Marathon, FL 33050

PERMIT NUMBER: FLA550973
 PA FILE NUMBER: FLA550973-001-DW2P/NP

B. Reuse and Land Application Systems

1. During the period beginning upon placing the new facilities into operation and lasting through the expiration date of this permit, the permittee is authorized to direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.10:

Monitoring Requirements										
Reclaimed Water Limitations										
Parameter	Units	Max/Min	Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow		Maximum	0.400	-	-	-	5 Days/Week	Calculated	CAL-02	See Cond.I.B.3
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	20.0	30.0	45.0	60.0	Every Two Weeks	Grab	EFF-01	
Solids, Total Suspended	MG/L	Maximum	-	-	-	5.0	4 Days/Week	Grab	EFB-01	
pH	SU	Range	-	-	-	6.0 to 8.5	5 Days/Week	Grab	EFA-01	
Coliform, Fecal, % less than detection	PERCENT	Minimum	See Permit Condition I.B.4.				4 Days/Week	Grab	EFA-01	
Coliform, Fecal	#/100ML	Maximum	See Permit Condition I.B.4.				4 Days/Week	Grab	EFA-01	
Total Residual Chlorine (For Disinfection)	MG/L	Minimum	-	-	-	1.0	Continuous	Meter	EFA-02	See Cond.I.B.5
Turbidity	NTU	Maximum	See Permit Condition I.B.6.				Continuous	Meter	EFB-01	
Giardia	CYSTS/100 L	Maximum	-	-	-	Report	Once every five years	Filtered	EFA-01	
Cryptosporidium	OOCYSTS/100 L	Maximum	-	-	-	Report	Once every five years	Filtered	EFA-01	

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I. B. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
CAL-02	Flow to reuse system is calculated by adding the two reuse turbine water meters. The meters shall be recorded daily in the plant log book.
EFA-01	At the exit end of the chlorine contact chambers just prior to discharge.
EFA-02	Continuous chlorine analyzer.
EFB-01	After filtration and prior to chlorination.

3. Meters shall be utilized to measure flow and calibrated at least annually. *[62-601.200(17) and .500(6)]*
4. Over a 30-day period, at least 75 percent of the fecal coliform values shall be below the detection limits. No sample shall exceed 25 fecal coliforms per 100 mL. No sample shall exceed 5.0 mg/L of total suspended solids (TSS) at a point before the application of the disinfectant. Note: To report the "% less than detection," count the number of fecal coliform observations that were less than detection, divide by the total number of fecal coliform observations in the month, and multiply by 100% (round to the nearest integer). *[62-600.440(5)(f)]*
5. The minimum total chlorine residual shall be limited as described in the approved operating protocol, such that the permit limitation for fecal coliform bacteria will be achieved. In no case shall the total chlorine residual be less than 1.0 mg/L. *[62-600.440(5)(b); 62-610.460(2); and 62-610.463(2)]*
6. The maximum turbidity shall be limited as described in the approved operating protocol, such that the permit limitations for total suspended solids and fecal coliforms will be achieved. *[62-610.463(2)]*

FACILITY: City of Marathon Area 4 WWT
 PERMITTEE: City of Marathon
 10045-55 Overseas Highway
 Marathon, FL 33050

PERMIT NUMBER: FLA550973
 PA FILE NUMBER: FLA550973-001-DW2P/NP

C. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning upon placing the new facilities into operation and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.10:

			Limitations				Monitoring Requirements			
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Parameter	Units	Max/Min								
Flow	MGD	Maximum	0.4	-	-	-	5 Days/Week	Meter	FLW-01	See Cond I.C.4
Percent Capacity, (TMADF/Permitted Capacity) x 100	PERCENT	Maximum	-	Report	-	-	Monthly	Calculated	CAL-01	
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	-	Report	-	-	Every Two Weeks	Grab	INF-01	See Cond.I.C.3
Solids, Total Suspended	MG/L	Maximum	-	Report	-	-	Every Two Weeks	Grab	INF-01	See Cond.I.C.3

FACILITY: City of Marathon Area 4 WWTP
 PERMITTEE: City of Marathon
 10045-55 Overseas Highway
 Marathon, FL 33050

PERMIT NUMBER: FLA550973
 PA FILE NUMBER: FLA550973-001-DW2P/NP

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I. C. 1 and as described below:

Monitoring Location Site Number	Description of Monitoring Location
CAL-01	Calculation for percent capacity.
FLW-01	On the influent pipe prior to the backwash and decant recycle piping.
INF-01	Influent sample point prior to the backwash and decant recycle piping.

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
4. Meters shall be utilized to measure flow and calibrated at least annually. [62-601.200(17) and .500(6)]
5. The treatment facilities shall be operated in accordance with all approved operating protocols. Only reclaimed water that meets the criteria established in the approved operating protocol(s) may be released to system storage or to the reuse system. Reclaimed water that fails to meet the criteria in the approved operating protocol(s) shall be directed to the following permitted alternate discharge system: two Class V injection wells located onsite. The operating protocol(s) shall be reviewed and updated periodically to ensure continuous compliance with the minimum treatment and disinfection requirements. Updated operating protocols shall be submitted to the Department for review and approval upon revision of the operating protocol(s) and with each permit application. [62-610.320(6) and 62-610.463(2)]
6. Instruments for continuous on-line monitoring of total residual chlorine and turbidity shall be equipped with an automated data logging or recording device. [62-610.463(2) & .865(8)(d)]
7. Intervals between sampling for Giardia and Cryptosporidium shall not exceed five years. Sampling results shall be reported on DEP Form 62-610.300(4)(a)4 which is attached to this permit. This form shall be submitted to the Department and to DEP's Reuse Coordinator in Tallahassee. [62-610.463(4)]
8. Parameters which must be monitored as a result of a surface water discharge shall be analyzed using a sufficiently sensitive method to assure compliance with applicable water quality standards and effluent limitations in accordance with 40 CFR (Code of Federal Regulations) Part 136. All monitoring shall be representative of the monitored activity. [62-620.320(6)]
9. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
10. Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department's South District Office Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e., monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type	Monitoring Period	Due Date
Monthly or Toxicity	first day of month – last day of month	28 th day of following month
Quarterly	January 1 - March 31	April 28
	April 1 – June 30	July 28
	July 1 – September 30	October 28
	October 1 – December 31	January 28
Semiannual	January 1 – June 30	July 28
	July 1 – December 31	January 28
Annual	January 1 – December 31	January 28

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

DMRs shall be submitted for each required monitoring period including months of no discharge. The permittee shall make copies of the attached DMR form(s) and shall submit the completed DMR form(s) to the Department's South District Office at the address specified in Permit Condition I.C. 14 by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18)][62-601.300(1), (2), and (3)]

11. During the period of operation authorized by this permit, reclaimed water or effluent shall be monitored annually for the primary and secondary drinking water standards contained in Chapter 62-550, F.A.C., (except for turbidity, color, and corrosivity). Twenty-four hour composite samples shall be used to analyze reclaimed water or effluent for the primary and secondary drinking water standards. These monitoring results shall be reported to the Department annually on the DMR. During years when a permit is not renewed, a certification stating that no new non-domestic wastewater dischargers have been added to the collection system since the last reclaimed water or effluent analysis was conducted may be submitted in lieu of the report. The annual reclaimed water or effluent analysis report or the certification shall be completed and submitted in a timely manner so as to be received by the South District Office by June 28 of each year. Approved analytical methods identified in Rule 62-620.100(3)(i), F.A.C., shall be used for the analysis. If no method is included for a parameter, methods specified in Chapter 62-550, F.A.C., shall be used. *[62-601.300(4)][62-601.500(3)][62-610.300(4)]*
12. The permittee shall submit an Annual Reuse Report using DEP Form 62-610.300(4)(a)2. on or before January 1 of each year. *[62-610.870(3)]*
13. The permittee shall maintain an inventory of storage systems. The inventory shall be submitted to the Department at least 30 days before reclaimed water will be introduced into any new storage system. The inventory of storage systems shall be attached to the annual submittal of the Annual Reuse Report. *[62-610.464(5)]*
14. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's South District Branch Office at the address specified below:

South District Branch Office
2796 Overseas Highway, Suite 221
Marathon, Florida 33050-4276

Phone Number - 305-289-2310

FAX Number - 305-289-2314 All FAX copies shall be followed by original copies. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. *[62-620.305]*

II. RESIDUALS MANAGEMENT REQUIREMENTS

1. The method of residuals use or disposal by this facility is transport to Cudjoe Key Transfer Station, Long Key Transfer Station, and Key Largo Transfer Station, or disposal in a Class I or II solid waste landfill.
2. The permittee shall be responsible for proper treatment, management, use, and land application or disposal of its residuals. *[62-640.300(5)]*
3. The permittee shall not be held responsible for treatment, management, use, or land application violations that occur after its residuals have been accepted by a permitted residuals management facility with which the source facility has an agreement in accordance with Rule 62-640.880(1)(c), F.A.C., for further treatment, management, use or land application. *[62-640.300(5)]*
4. Disposal of residuals, septage, and other solids in a solid waste landfill, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. *[62-640.100(6)(k)3 & 4]*

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

5. If the permittee intends to accept residuals from other facilities, a permit revision is required pursuant to Rule 62-640.880(2)(d), F.A.C. [62-640.880(2)(d)]
6. The permittee shall keep hauling records to track the transport of residuals between facilities. The hauling records shall contain the following information:

Source Facility	Residuals Management Facility or Treatment Facility
1. Date and Time Shipped	1. Date and Time Received
2. Amount of Residuals Shipped	2. Amount of Residuals Received
3. Degree of Treatment (if applicable)	3. Name and ID Number of Source Facility
4. Name and ID Number of Residuals Management Facility or Treatment Facility	4. Signature of Hauler
5. Signature of Responsible Party at Source Facility	5. Signature of Responsible Party at Residuals Management Facility or Treatment Facility
6. Signature of Hauler and Name of Hauling Firm	

These records shall be kept for five years and shall be made available for inspection upon request by the Department. A copy of the hauling records information maintained by the source facility shall be provided upon delivery of the residuals to the residuals management facility or treatment facility. The permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of residuals leaving the source facility and arriving at the residuals management facility or treatment facility. [62-640.880(4)]

7. Storage of residuals or other solids at the permitted facility shall require prior written notification to the Department. [62-640.300(4)]

III. GROUND WATER REQUIREMENTS

Construction Requirements

1. The permittee shall give at least 72-hours notice to the Department's South District Office, prior to the installation of any monitoring wells detailed in this permit. [62-4.070]
2. The QUARTERLY sampling and analysis of all new ground water monitoring wells shall begin upon proper completion of the GWMP well system. The wells shall be sampled for the parameters identified in Permit Condition III.13 and in accordance to the Department's "Standard Operating Procedures For Laboratory Operations and Sample Collection Activities," DEP-SOP-001/01, FS 2200 Ground water Sampling, January 1, 2002. [62-522.600(1) , (11)(a), and (b)]
3. Prior to construction of new ground water monitoring wells, a soil boring shall be made at each new monitoring well location in order to establish the well depth and screen interval. [62-522.900(3)]
4. Within thirty days after completion of construction of the ground water monitoring wells, a properly scaled figure depicting monitor well locations (active and abandoned) with identification numbers shall be submitted. The figure shall also include (or attached) the monitoring well, top of casing and ground surface elevations referenced to North American Vertical Datum (NAVD) to the nearest 0.1 foot, along with monitor well location latitude and longitude to the nearest 0.1 second. 62-610.412 (c)
5. Within thirty days after completion of construction of the ground water monitoring wells, well completion reports shall be sent to the Domestic Wastewater Section, FDEP South District Office. The information is to be submitted on the attached form for each well, DEP Form 62-522.900(3), Monitor Well Completion Report. [62-522.900(3)]
6. In Districts, where applicable, within 30 days of completion of construction of new ground water monitor wells, the Department requests that the permittee submit the following information for each monitor well :
 - a. A copy of the Florida Water Management District, (WMD), State of Florida Permit Application to Construct, Repair, Modify or Abandon a Well, Form 41.10-410(1), and

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

b. A copy of the WMD Well Completion Report, Form 41.10-410(2), 62-610.412(2)(b)

7. Prior to the application of effluent to the reuse/disposal site, the permittee shall sample all new ground water monitoring wells for the Primary and Secondary Drinking Water parameters included in Rule 62-550, Florida Administrative Code, Public Drinking Water Systems (excluding asbestos, acrylamide dioxin, butachlor and epichlorohydrin), and EPA Methods 601 and 602. [62-520.400 and 62-520.420] [62-522.300(1), and 62-522.600(3)(A)]
8. The permittee shall coordinate any expansion of the Part IV reclaimed water reuse system with the South District Domestic Waste Permitting Section and shall propose additional ground water monitoring that may be required due to such expansion. All new ground water monitoring wells that may subsequently be required shall be identified in a revision to the GWMP and shall be installed within 90 days of Department approval of the GWMP revision. The permittee shall apply for a major revision to this permit to incorporate the selected wells and to provide appropriate DMR section D pages. [62-522.600(11)(C) and 62-610.320(3)]

Operational Requirements

9. For the Part IV land application system(s), all ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge for this project shall extend horizontally 100 feet from the application site or to the facility's property line, whichever is less, and vertically to the base of the surficial aquifer. [62-520.200(23)][62-522.400 and 62-522.410]
10. The ground water minimum criteria specified in Rule 62-520.400 F.A.C., shall be met within the zone of discharge. [62-520.400 and 62-520.420(4)]
11. Upon placing newly expanded R-001 into operation, the permittee shall begin sampling ground water in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-522.600, F.A.C. [62-522.600(3) and (5)].
12. The following monitoring wells shall be sampled in accordance with the monitoring frequencies specified in Permit Condition III.13. for Reuse System R-001. Sampling must be reasonably spaced to be representative of potentially changing conditions.

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Depth (Feet)	Aquifer Monitored	New or Existing
MWC-1	MWC-87284	15	Surficial	New

MWC = Compliance
[62-522.600][62-610.412]

13. The following parameters shall be analyzed for each of the monitoring well(s) identified in Permit Condition(s) III. 12.

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Water Level Relative to NGVD	Report	FEET	In-situ	Quarterly
Nitrogen, Nitrate, Total (as N)	10	MG/L	Grab	Quarterly
Solids, Total Dissolved (TDS)	500	MG/L	Grab	Quarterly
Arsenic, Total Recoverable	10	UG/L	Grab	Quarterly
Chloride (as Cl)	250	MG/L	Grab	Quarterly
Cadmium, Total Recoverable	5	UG/L	Grab	Quarterly
Chromium, Total Recoverable	100	UG/L	Grab	Quarterly
Lead, Total Recoverable	15	UG/L	Grab	Quarterly
Coliform, Fecal	4	#/100ML	Grab	Quarterly
pH	6.5 to 8.5	SU	In-situ	Quarterly

FACILITY: City of Marathon Area 4 WWTP
 PERMITTEE: City of Marathon
 10045-55 Overseas Highway
 Marathon, FL 33050

PERMIT NUMBER: FLA550973
 PA FILE NUMBER: FLA550973-001-DW2P/NP

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Sulfate, Total	250	MG/L	Grab	Quarterly
Turbidity	Report	NTU	Grab	Quarterly
Sodium, Dissolved	160	MG/L	Grab	Quarterly
Specific Conductance	Report	UMHO/CM	In-situ	Quarterly
Temperature (C), Water	Report	DEG.C	In-situ	Quarterly
Dissolved Oxygen	Report	MG/L	In-situ	Quarterly

[62-522.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601][62-601.300(6)] [62-520.300(9)]

14. If the concentration for any constituent listed in Permit Condition III. 13. in the natural background quality of the ground water is greater than the stated maximum, or in the case of pH is also less than the minimum, the representative natural background quality shall be the prevailing standard. [62-520.420(2)]
15. In accordance with Part D of Form 62-620.910(10), water levels shall be recorded before evacuating wells for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NAVD allowable) at a precision of plus or minus 0.1 foot. [62-610.412(2)(c)]
16. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples. [62-601.700(5)]
17. Analyses shall be conducted on unfiltered samples, unless filtered samples have been approved by the Department's South District Office as being more representative of ground water conditions. [62-520.300(9)]
18. Ground water monitoring parameters shall be analyzed in accordance with Chapter 62-601, F.A.C. [62-620.610(18)]
19. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10). For reuse or land application projects, results shall be submitted with the DMR for each month listed in the following schedule. The submitted results shall be for each year during the period of operation allowed by this permit in accordance with Permit Condition I.B.7. [62-522.600(10) and (11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-620.610(18)]

SAMPLE PERIOD	REPORT DUE DATE
January - March	April 28
April - June	July 28
July - September	October 28
October - December	January 28

20. If any monitoring well becomes damaged or cannot be sampled for some reason, the permittee shall notify the Department's South District Office immediately and a written report shall follow within seven days detailing the circumstances and remedial measures taken or proposed. Repair or replacement of monitoring wells shall be approved in advance by the Department's South District Office. [62-522.600][62-4.070(3)]
21. The Permittee shall provide verbal notice to the Department's South District Office as soon as practical after discovery of a sinkhole within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The Permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department's Southwest District Office in a written report within 7 days of the sinkhole discovery. [62-4.070(3)]
22. All piezometers and monitoring wells not part of the approved ground water monitoring plan are to be plugged and abandoned in accordance with Rule 62-532.500(4), F.A.C., unless there is intent for their future use. [62-532.500(4)]

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

Part III Public Access System(s) (R-001)

1. This reuse system includes the following users:

User Name	User Type	Capacity (MGD)	Acreage
Sombrero Country Club	Golf Courses	1.04	135
Sombrero Beach Park	Athletic Complexes and Parks	0.039	5
Marathon High School	Other Landscape Irrigation	0.039	5
Florida Keys Aqueduct Authority	Other Landscape Irrigation	0.016	2.1
Totals		1.134	147.1

[62-610.800(5)][62-620.630(10)(b)]

2. Cross-connections to the potable water system are prohibited. [62-610.469(7)]
3. A cross-connection control program shall be implemented and/or remain in effect within the areas where reclaimed water will be provided for use. [62-610.469(7)]
4. The permittee shall conduct inspections within the reclaimed water service area to verify proper connections, to minimize illegal cross-connections, and to verify the proper use of reclaimed water. Inspections are required when a customer first connects to the reuse distribution system. Subsequent inspections are required as specified in the cross-connection control and inspection program. [62-610.469(7)(h)]
5. If a cross-connection between the potable and reclaimed water systems is discovered, the permittee shall:
- Immediately discontinue potable water and/or reclaimed water service to the affected area.
 - If the potable water system is contaminated, clear the potable water lines.
 - Eliminate the cross-connection.
 - Test the affected area for other possible cross-connections.
 - Within 24 hours, notify the South District Office's domestic wastewater and drinking water programs.
 - Within 5 days of discovery of a cross-connection, submit a written report to the Department detailing: a description of the cross-connection, how the cross-connection was discovered, the exact date and time of discovery, approximate time that the cross-connection existed, the location, the cause, steps taken to eliminate the cross-connection, whether reclaimed water was consumed, and reports of possible illness, whether the drinking water system was contaminated and the steps taken to clear the drinking water system, when the cross-connection was eliminated, plan of action for testing for other possible cross-connections in the area, and an evaluation of the cross-connection control and inspection program to ensure that future cross-connections do not occur. [62-555.350(3) and 62-555.360][62-620.610(20)]
6. Maximum obtainable separation of reclaimed water lines and potable water lines shall be provided and the minimum separation distances specified in Rule 62-610.469(7), F.A.C., shall be provided. Reuse facilities shall be color coded or marked. Underground piping which is not manufactured of metal or concrete shall be color-coded using Pantone Purple 522C using light stable colorants. Underground metal and concrete pipe shall be color-coded or marked using purple as the predominant color. [62-610.469(7)]

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

7. In constructing reclaimed water distribution piping, the permittee shall maintain a 75-foot setback distance from a reclaimed water transmission facility to public water supply wells. No setback distances are required to other potable water supply wells or to any nonpotable water supply wells. *[62-610.471(3)]*
8. A setback distance of 75 feet shall be maintained between the edge of the wetted area and potable water supply wells, unless the utility adopts and enforces an ordinance prohibiting potable water supply wells within the reuse service area. No setback distances are required to any nonpotable water supply well, to any surface water, to any developed areas, or to any private swimming pools, hot tubs, spas, saunas, picnic tables, barbecue pits, or barbecue grills. *[62-610.471(1), (2), (5), and (7)]*
9. Reclaimed water shall not be used to fill swimming pools, hot tubs, or wading pools. *[62-610.469(4)]*
10. Low trajectory nozzles, or other means to minimize aerosol formation shall be used within 100 feet from outdoor public eating, drinking, or bathing facilities. *[62-610.471(6)]*
11. A setback distance of 100 feet shall be maintained from indoor aesthetic features using reclaimed water to adjacent indoor public eating and drinking facilities. *[62-610.471(8)]*
12. The public shall be notified of the use of reclaimed water. This shall be accomplished by posting of advisory signs in areas where reuse is practiced, notes on scorecards, or other methods. *[62-610.468(2)]*
13. All advisory signs and labels on vaults, service boxes, or compartments that house hose bibbs along with all labels on hose bibbs, valves, and outlets shall bear the words "do not drink" and "no beber" along with the equivalent standard international symbol. In addition to the words "do not drink" and "no beber," advisory signs posted at storage ponds and decorative water features shall also bear the words "do not swim" and "no nadar" along with the equivalent standard international symbols. *[62-610.468 & .469]*
14. The permittee shall ensure that users of reclaimed water are informed about the origin, nature, and characteristics of reclaimed water; the manner in which reclaimed water can be safely used; and limitations on the use of reclaimed water. Notification is required at the time of initial connection to the reclaimed water distribution system and annually after the reuse system is placed into operation. A description of on-going public notification activities shall be included in the Annual Reuse Report. *[62-610.468(6)]*
15. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. *[62-610.414 & 62-610.464]*
16. Overflows from emergency discharge facilities on storage ponds shall be reported as an abnormal event to the Department's South District Office within 24 hours of an occurrence. The provisions of Rule 62-610.800(9), F.A.C., shall be met. *[62-610.800(9)]*
17. The facility shall have continuous chlorine and turbidity monitoring with automatic diversion to the injection wells when the reuse criteria are not met. *[62-610.462(2)]*
18. Prior to initial application of reclaimed water, the permittee shall submit to the Department an agreement between the users of the reclaimed water and the permittee that shall ensure that construction, operation, maintenance, and monitoring meet the requirements of Chapter 62-610, FAC. Please note that the permittee shall retain primary responsibility for ensuring compliance with all requirements of the Florida Administrative Code. *[62-610.469(2), FAC]*

V. OPERATION AND MAINTENANCE REQUIREMENTS

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of an operator certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category I, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 6 hours/day for 7 days/week. The lead operator must be a Class C, or higher.

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050
[62-620.630(3)] [62-699.310] [62-610.462]

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

2. An operator meeting the lead operator classification level of the plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. [62-699.311(1)]
3. When the three-month average daily flow for the most recent three consecutive months exceeds 50 percent of the permitted capacity of the treatment plant or reuse and disposal systems, the permittee shall submit to the Department a capacity analysis report. This initial capacity analysis report shall be submitted within 180 days after the last day of the last month of the three-month period referenced above. The capacity analysis report shall be prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(4)]
4. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1)]
5. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility:
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation and a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current permit;
 - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
 - g. A copy of the facility record drawings;
 - h. Copies of the licenses of the current certified operators; and
 - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and certification number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities; tests performed and samples taken; and major repairs made. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed.

[62-620.350]

VI. SCHEDULES

1. The following construction schedule for the facilities shall be followed, unless a minor permit revision is issued to amend the schedule:

Implementation Step		Completion Date
1	Begin construction	Upon permit issuance

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

Implementation Step		Completion Date
2	End construction.	September 1, 2009
3	Begin reuse or disposal.	December 1, 2009
4	Attain operational level.	April 30, 2010
5	Submit to the Department an agreement between the permittee and end users of reclaimed water that shall ensure that construction, operation, maintenance, and monitoring meet the requirements of Chapter 62-610, FAC.	Prior to beginning reuse. Section VI is not applicable to this facility.

[62-620.400]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

This facility is not required to have a pretreatment program at this time. [62-625.500]

VIII. OTHER SPECIFIC CONDITIONS

1. Prior to placing the new facilities into operation or any individual unit processes into operation, for any purpose other than testing for leaks and equipment operation, the permittee shall complete and submit to the Department DEP Form 62-620.910(12), Notification of Completion of Construction for Domestic Wastewater Facilities. [62-620.630(2)]
2. The newly constructed Part III reuse system shall not be placed in service for any purpose without written approval from the Department. For projects identified in the permit as being constructed in phases, written permission is only required for the first phase. Application for approval shall be made to the Department on DEP Form 62-610.300(4)(a)3, Application for Permission to Place a Public Access Reuse System in Operation. In addition, the users' agreement specified in Permit Condition IV. 18. shall be submitted prior to approval. [62-610.800(7) & 62-610.469(2), FAC]
3. Within six months after a facility is placed in operation, the permittee shall provide written certification to the Department on Form 62-620.910(13) that record drawings pursuant to Chapter 62-600, F.A.C., and that an operation and maintenance manual pursuant to Chapters 62-600 and 62-610, F.A.C., as applicable, are available at the location specified on the form. [62-620.630(7)]
4. The permittee shall apply for renewal of this permit at least 180 days before the expiration date of the permit using the appropriate forms listed in Rule 62-620.910, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C. The existing permit shall not expire until the Department has taken final action on the application renewal in accordance with the provisions of 62-620.335(3) and (4), F.A.C. [62-620.335(1)-(4)]
5. Florida water quality criteria and standards shall not be violated as a result of any discharge or land application of reclaimed water or residuals from this facility. [62-610.850(1)(a) and (2)(a)]
6. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. [62-600.410(8) and 62-640.400(6)]
7. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. [62-604.130(3)]

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

8. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.550] [62-620.610(20)]
9. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health or safety problems.[62-604.130(5)]
10. The treatment facility, storage ponds, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-600.400(2)(b)]
11. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-701.300(1)(a)]
12. The Permittee shall provide verbal notice to the Department as soon as practical after discovery of a sinkhole within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The Permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department in a written report within 7 days of the sinkhole discovery. [62-4.070(3)]
13. The permittee shall provide adequate notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C. if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2)]

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. *[62-620.610(3)]*
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. *[62-620.610(4)]*
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. *[62-620.610(5)]*
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. *[62-620.610(6)]*
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. *[62-620.610(7)]*
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. *[62-620.610(8)]*
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.*[62-620.610(9)]*
10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, Florida Statutes, or Rule 62-620.302, Florida Administrative Code. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10)]*
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit,

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11)]*

12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12)]*
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13)]*
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14)]*
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15)]*
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300 and the Department of Environmental Protection Guide to Wastewater Permitting at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2) for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. *[62-620.610(16)]*
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.*[62-620.610(17)]*
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.

- e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
- f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220 and 62-160.330, F.A.C.

[62-620.610(18)]

- 19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. *[62-620.610(19)]*
- 20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 - a. The following shall be included as information which must be reported within 24 hours under this condition:
 - 1. Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - 2. Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - 3. Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - 4. Any unauthorized discharge to surface or ground waters.
 - b. Oral reports as required by this subsection shall be provided as follows:
 - 1. For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph a.4 that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the Department by calling the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - a) Name, address, and telephone number of person reporting;
 - b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - e) Estimated amount of the discharge;
 - f) Location or address of the discharge;
 - g) Source and cause of the discharge;
 - h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - i) Description of area affected by the discharge, including name of water body affected, if any; and

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

j) Other persons or agencies contacted.

2. Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report.

[62-620.610(20)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX. 17., 18. and 19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX. 20 of this permit. [62-620.610(21)]

22. Bypass Provisions.

- a. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 3. The permittee submitted notices as required under Permit Condition IX. 22. b. of this permit.
- b. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX. 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- c. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX. 22. a. 1. through 3. of this permit.
- d. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX. 22. a. through c. of this permit.

[62-620.610(22)]

23. Upset Provisions

- a. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 1. An upset occurred and that the permittee can identify the cause(s) of the upset;
 2. The permitted facility was at the time being properly operated;
 3. The permittee submitted notice of the upset as required in Permit Condition IX. 20. of this permit; and
 4. The permittee complied with any remedial measures required under Permit Condition IX. 5. of this permit.

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

- b. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- c. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

X. Injection Wells:

I. General Criteria

- (a) The terms, conditions, requirements, limitations and restrictions set forth in this permit are "permit conditions" and are binding and enforceable pursuant to section 403.141, F.S.
- (b) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action.
- (c) As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
- (d) This permit conveys no title to land, water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (e) This permit does not relieve the permittee from liability for harm to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefrom; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
- (f) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, or are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (g) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
 - 1. Have access to and copy any records that must be kept under conditions of this permit;
 - 2. Inspect the facility, equipment, practices, or operations regulated or required under this permit; and
 - 3. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.Reasonable time will depend on the nature of the concern being investigated.
- (h) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
 - 1. A description of and cause of noncompliance; and
 - 2. The period of noncompliance, including dates and times; or, if not corrected the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent the recurrence of the noncompliance. The permittee shall be responsible for any and all damages which

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

- (i) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (j) The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
- (k) This permit is transferable only upon Department approval in accordance with rules 62-4.120 and 62-528.350, F.A.C. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (l) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (m) The permittee shall comply with the following;
 - 1. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records shall be extended automatically unless the Department determines that the records are no longer required.
 - 2. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - 3. Records of monitoring information shall include:
 - a. the date, exact place, and time of sampling or measurements;
 - b. the person responsible for performing the sampling or measurements;
 - c. the dates analyses were performed;
 - d. the person responsible for performing the analyses;
 - e. the analytical techniques or methods used;
 - f. the results of such analyses.
 - 4. The permittee shall furnish to the Department, within the time requested in writing, any information which the Department requests to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit.
 - 5. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.
- (n) All applications, reports, or information required by the Department shall be certified as being true, accurate, and complete.
- (o) Reports of compliance or noncompliance with, or any progress reports on, requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each scheduled date.
- (p) Any permit noncompliance constitutes a violation of the Safe Drinking Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- (q) It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

- (r) The permittee shall take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit.
- (s) This permit may be modified, revoked and reissued, or terminated for cause, as provided in 40 C.F.R. sections 144.39(a), 144.40(a), and 144.41 (1998). The filing of a request by the permittee for a permit modification, revocation or reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- (t) The permittee shall give advance notice to the Department of any planned changes in the permitted facility or injection activity which may result in noncompliance with permit requirements.
- (u) The permittee shall report any noncompliance which may endanger health or the environment including:
 - 1. Any monitoring or other information which indicates that any contaminant may cause an endangerment to an underground source of drinking water; adjacent surface waters, or
 - 2. Any noncompliance with a permit condition or malfunction of the injection system which may cause fluid migration into or between underground sources of drinking water. Any noncompliance with a permit condition or malfunction of the injection system which may cause migration of untreated or partially treated fluids into ground waters or adjacent surface waters of the State. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause, the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- (v) Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures.
- (w) No underground injection is allowed that causes or allows movement of fluid into an underground source of drinking water if such fluid movement may cause a violation of any primary drinking water standard or may otherwise adversely affect the health of persons and or cause an exceedance of the minimum criteria for ground or surface waters of the State.

2. Signatories and Certification Requirements_

- 1. All reports and other submittals required to comply with this permit shall be signed by a person authorized under Rules 62-528.340(1) or (2), F.A.C.
- 2. In accordance with Rule 62-528.340(4), F.A.C., all reports shall contain the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based upon my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

3. The Certification of Class V well Construction Completion, DEP Form 62-528.900(4) and the Well Completion Report from the appropriate Water Management District shall be submitted by the licensed well driller within 30 days after completion of construction or abandonment.

4. Copies of well completion report are to be mailed to the following:

- a. Department of Environmental Protection, South Florida District, P.O. Box 2549, Fort Myers, Florida 33902-2549.
- b. South Florida Water Management District, Water Use Division, Post Office Box 24680,

FACILITY: City of Marathon Area 4 WWTP
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050
West Palm Beach, Florida 33416-4680.

PERMIT NUMBER: FLA550973
PA FILE NUMBER: FLA550973-001-DW2P/NP

c. Bureau of Geology, 903 N. Tennessee Street, Tallahassee, Florida 32307.

5. In the event a well must be plugged or abandoned, the permittee shall obtain a permit from the Department as required by Sections 62-528.625 and 62-528.645, F.A.C.

6. The permittee shall notify the Department and obtain approval prior to any well work or modification.


7. The permittee is reminded of the necessity to comply with the pertinent regulations of any other regulatory agency, as well as any county, municipal, and federal regulations applicable to the project. These regulations may include, but are not limited to, those of the Federal Emergency Management Agency in implementing flood control measures. This permit should not be construed to imply compliance with the rules and regulations of other regulatory agencies.

8. The permittee shall notify the Department's Marathon branch office at (305) 289-2310, 48 hours prior to any annular space cementing of the Class V wells which may be deemed necessary during construction.

Note: In the event of an emergency the permittee shall contact the Department by calling (800) 320-0519. The permittee shall call (239) 332-6975 during regular business hours.

Executed in Fort Myers, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL
PROTECTION



Jon M. Iglehart
Director of District Management

DATE: September 11, 2007



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, Florida 33902-2549

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:

City of Marathon

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-001-DW2P
ISSUANCE DATE: October 1, 2007
EXPIRATION DATE: September 30, 2012

RESPONSIBLE AUTHORITY:

Mr. Michael Puto
City Manager
10045-55 Overseas Highway
Marathon, FL 33050
(305) 289-4130

FACILITY:

City of Marathon Area 6
Avenue 1
Marathon, FL 33050
Monroe County
Latitude: 24° 43' 51" N Longitude: 81° 0' 15" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). The above named permittee is hereby authorized to construct and operate the facilities shown on the application and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

TREATMENT FACILITIES:

The facility is a new advanced domestic wastewater treatment plant with a permitted capacity of 0.200 million gallons per day (MGD) annual average daily flow (AADF). The facility is a sequencing batch reactor consisting of influent screening, aeration, chemical feed, filtration, final sedimentation, chlorination, and denitrification. It has three 105,086 gallon batch tanks, one 25,000 gallon effluent equalization tank, and one 98,000 gallon aerobic digester.

Filtration and disinfection occurs in two units. Each unit has a filter surface area of 72 square feet and a 3,750 gallon chlorine contact chamber. The facility has a 5,300 gallon mudwell for the filter backwash. Disinfection is met using sodium hypochlorite.

DISPOSAL:

Underground Injection: An existing 0.2 MGD AADF permitted capacity injection well system U-001 consisting of three Class V, Group 3, injection wells permitted under Department permit numbers 78201-004, -005, and -006 – UO/5W discharging to Class G-III ground water. U-001 is located approximately at latitude 24 ° 43' 50" N, longitude 81 ° 0' 15" W.

IN ACCORDANCE WITH: The limitations, monitoring requirements and other conditions set forth in Pages 1 through 17 of this permit.

FACILITY: City of Marathon Area 6 PERMIT NUMBER: FLA579033
 PERMITTEE: City of Marathon PA FILE NUMBER: FLA579033-DW2P/NP
 10045-55 Overseas Highway
 Marathon, FL 33050

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Underground Injection Control Systems

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge effluent to injection well system U-001 located at the plant. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7:

Monitoring Requirements										
			Effluent Limitations							
Parameter	Units	Max/Min	Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	5.0	6.25	7.5	10.0	Every Two Weeks	8-hour flow proportioned composite	EFF-1	
Solids, Total Suspended	MG/L	Maximum	5.0	6.25	7.5	10.0	Every Two Weeks	8-hour flow proportioned composite	EFF-1	
pH	SU	Range	-	-	-	6.0 to 8.5	5 Days/Week	Grab	EFF-1	
Coliform, Fecal	See Permit Condition I.A.3.						Every Two Weeks	Grab	EFF-1	
Total Residual Chlorine (For Disinfection)	MG/L	Minimum	-	-	-	0.5	5 Days/Week	Grab	EFA-1	See Cond I.A.4
Nitrogen, Total (as N)	MG/L	Maximum	3.0	3.75	4.5	6.0	Every Two Weeks	8-hour flow proportioned composite	EFF-1	
Phosphorus, Total (as P)	MG/L	Maximum	1.0	1.25	1.5	2.0	Every Two Weeks	8-hour flow proportioned composite	EFF-1	

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

2. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I. A. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
EFA-1	Chlorine analyzer located after the chlorine contact basins.
EFF-1	Effluent sampler on the effluent pipe to the injection wells.

3. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed 200 per 100 mL of effluent sample. The geometric mean of the fecal coliform values for a minimum of 10 samples of effluent each collected on a separate day during a period of 30 consecutive days (monthly), shall not exceed 200 per 100 mL of sample. No more than 10 percent of the samples collected (the 90th percentile value) during a period of 30 consecutive days shall exceed 400 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 800 fecal coliform values per 100 mL of sample. Note: To report the 90th percentile value, list the fecal coliform values obtained during the month in ascending order. Report the value of the sample that corresponds to the 90th percentile (multiply the number of samples by 0.9). For example, for 30 samples, report the corresponding fecal coliform number for the 27th value of ascending order. [62-600.440(4)(c)]
4. A minimum of 0.5 mg/L total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-600.440(4)(b)]

FACILITY: City of Marathon Area 6
 PERMITTEE: City of Marathon
 10045-55 Overseas Highway
 Marathon, FL 33050

PERMIT NUMBER: FLA579033
 PA FILE NUMBER: FLA579033-DW2P/NP

B. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning upon placing the new facilities into operation and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7:

Monitoring Requirements										
Limitations										
Parameter	Units	Max/Min	Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow	MGD	Maximum	0.2	-	-	-	5 Days/Week	Meter	FLW-1	See Cond I.B.4
Percent Capacity, (TMADP/Permitted Capacity) x 100	PERCENT	Maximum	-	Report	-	-	Monthly	Calculated	CAL-1	
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	-	Report	-	-	Every Two Weeks	Grab	INF-1	See Cond I.B.3
Solids, Total Suspended	MG/L	Maximum	-	Report	-	-	Every Two Weeks	Grab	INF-1	See Cond I.B.3

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I. B. 1 and as described below:

Monitoring Location Site Number	Description of Monitoring Location
CAL-1	Calculation for percent capacity.
FLW-1	Transit time Doppler type flowmeter strapped on the influent pipe.
INF-1	Influent sampler before the barscreen.

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
4. Meters shall be utilized to measure flow and calibrated at least annually. [62-601.200(17) and .500(6)]
5. Parameters which must be monitored as a result of a surface water discharge shall be analyzed using a sufficiently sensitive method to assure compliance with applicable water quality standards and effluent limitations in accordance with 40 CFR (Code of Federal Regulations) Part 136. All monitoring shall be representative of the monitored activity. [62-620.320(6)]
6. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
7. Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department's South District Office Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e., monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type	Monitoring Period	Due Date
Monthly or Toxicity	First day of month – last day of month	28 th day of following month
Quarterly	January 1 - March 31 April 1 – June 30 July 1 – September 30 October 1 – December 31	April 28 July 28 October 28 January 28
Semiannual	January 1 – June 30 July 1 – December 31	July 28 January 28
Annual	January 1 – December 31	January 28

DMRs shall be submitted for each required monitoring period including months of no discharge. The permittee shall make copies of the attached DMR form(s) and shall submit the completed DMR form(s) to the Department's South District Office at the address specified in Permit Condition I.B. 8 by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18)][62-601.300(1), (2), and (3)]

8. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's South District Office at the address specified below:

Florida Department of Environmental Protection
Marathon Regional Service Center
2796 Overseas Highway, Suite 221
Marathon, Florida 33050-2227

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

Phone Number - (305) 289-2310

FAX Number - (305) 289-2314 All FAX copies shall be followed by original copies. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. [62-620.305]

II. RESIDUALS MANAGEMENT REQUIREMENTS

1. The method of residuals use or disposal by this facility is transport to Cudjoe Key Transfer Station, Long Key Transfer Station, and Key Largo Transfer Station or disposal in a Class I or II solid waste landfill.
2. The permittee shall be responsible for proper treatment, management, use, and land application or disposal of its residuals. [62-640.300(5)]
3. The permittee shall not be held responsible for treatment, management, use, or land application violations that occur after its residuals have been accepted by a permitted residuals management facility with which the source facility has an agreement in accordance with Rule 62-640.880(1)(c), F.A.C., for further treatment, management, use or land application. [62-640.300(5)]
4. Disposal of residuals, septage, and other solids in a solid waste landfill, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. [62-640.100(6)(k)3 & 4]
5. If the permittee intends to accept residuals from other facilities, a permit revision is required pursuant to Rule 62-640.880(2)(d), F.A.C. [62-640.880(2)(d)]
6. The permittee shall keep hauling records to track the transport of residuals between facilities. The hauling records shall contain the following information:

Source Facility

1. Date and Time Shipped
2. Amount of Residuals Shipped
3. Degree of Treatment (if applicable)
4. Name and ID Number of Residuals Management Facility or Treatment Facility
5. Signature of Responsible Party at Source Facility
6. Signature of Hauler and Name of Hauling Firm

Residuals Management Facility or Treatment Facility

1. Date and Time Received
2. Amount of Residuals Received
3. Name and ID Number of Source Facility
4. Signature of Hauler
5. Signature of Responsible Party at Residuals Management Facility or Treatment Facility

These records shall be kept for five years and shall be made available for inspection upon request by the Department. A copy of the hauling records information maintained by the source facility shall be provided upon delivery of the residuals to the residuals management facility or treatment facility. The permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of residuals leaving the source facility and arriving at the residuals management facility or treatment facility. [62-640.880(4)]

7. Storage of residuals or other solids at the permitted facility shall require prior written notification to the Department. [62-640.300(4)]

III. GROUND WATER REQUIREMENTS

Construction Requirements

Section Construction Requirements is not applicable to this facility.

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

Operational Requirements

1. The ground water minimum criteria specified in Rule 62-520.400 F.A.C., shall be met within the zone of discharge. *[62-520.400 and 62-520.420(4)]*
2. Ground water monitoring for U-001 shall be in accordance with permit numbers 78201-004, 78201-005, and 78201-006- UO/5W.

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

Section IV is not applicable to this facility.

V. OPERATION AND MAINTENANCE REQUIREMENTS

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of an operator certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category I, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 6 hours/day for 5 days/week and one visit on each weekend day. The lead operator must be a Class C operator, or higher.

[62-620.630(3)] [62-699.310] [62-610.462]

2. An operator meeting the lead operator classification level of the plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. *[62-699.311(1)]*
3. When the three-month average daily flow for the most recent three consecutive months exceeds 50 percent of the permitted capacity of the treatment plant or reuse and disposal systems, the permittee shall submit to the Department a capacity analysis report. This initial capacity analysis report shall be submitted within 180 days after the last day of the last month of the three-month period referenced above. The capacity analysis report shall be prepared in accordance with Rule 62-600.405, F.A.C. *[62-600.405(4)]*
4. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. *[62-600.735(1)]*
5. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility:
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation and a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current permit;
 - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

- g. A copy of the facility record drawings;
- h. Copies of the licenses of the current certified operators; and
- i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and certification number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities; tests performed and samples taken; and major repairs made. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed.

[62-620.350]

VI. SCHEDULES

1. The following construction schedule for the facilities shall be followed, unless a minor permit revision is issued to amend the schedule:

Implementation Step		Completion Date
1	Begin construction	Upon permit issuance
2	End construction	September 1, 2008
3	Begin disposal	October 30, 2008
4	Attain operational levels	December 30, 2008

[62-620.400]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

This facility is not required to have a pretreatment program at this time. [62-625.500]

VIII. OTHER SPECIFIC CONDITIONS

1. Prior to placing the new facilities into operation or any individual unit processes into operation, for any purpose other than testing for leaks and equipment operation, the permittee shall complete and submit to the Department DEP Form 62-620.910(12), Notification of Completion of Construction for Domestic Wastewater Facilities. [62-620.630(2)]
2. Within six months after a facility is placed in operation, the permittee shall provide written certification to the Department on Form 62-620.910(13) that record drawings pursuant to Chapter 62-600, F.A.C., and that an operation and maintenance manual pursuant to Chapters 62-600 and 62-610, F.A.C., as applicable, are available at the location specified on the form. [62-620.630(7)]
3. The permittee shall apply for renewal of this permit at least 180 days before the expiration date of the permit using the appropriate forms listed in Rule 62-620.910, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C. The existing permit shall not expire until the Department has taken final action on the application renewal in accordance with the provisions of 62-620.335(3) and (4), F.A.C. [62-620.335(1)-(4)]
4. Florida water quality criteria and standards shall not be violated as a result of any discharge or land application of reclaimed water or residuals from this facility.
5. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. [62-600.410(8) and 62-640.400(6)]

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

6. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. [62-604.130(3)]
7. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.550] [62-620.610(20)]
8. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health or safety problems.[62-604.130(5)]
9. The treatment facility, storage ponds, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-600.400(2)(b)]
10. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-701.300(1)(a)]
11. The Permittee shall provide verbal notice to the Department as soon as practical after discovery of a sinkhole within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The Permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department in a written report within 7 days of the sinkhole discovery. [62-4.070(3)]
12. The permittee shall provide adequate notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C. if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2)]

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]

2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5)]
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. [62-620.610(6)]
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7)]
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8)]
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, Florida Statutes, or Rule 62-620.302, Florida Administrative Code. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. [62-620.610(10)]

11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. [62-620.610(11)]
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. [62-620.610(12)]
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. [62-620.610(13)]
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. [62-620.610(14)]
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. [62-620.610(15)]
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300 and the Department of Environmental Protection Guide to Wastewater Permitting at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2) for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16)]
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.[62-620.610(17)]
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

- c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
- d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
- e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
- f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220 and 62-160.330, F.A.C.

[62-620.610(18)]

19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. *[62-620.610(19)]*
20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 - a. The following shall be included as information which must be reported within 24 hours under this condition:
 1. Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 2. Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 3. Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 4. Any unauthorized discharge to surface or ground waters.
 - b. Oral reports as required by this subsection shall be provided as follows:
 1. For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph a.4 that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the Department by calling the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - a) Name, address, and telephone number of person reporting;
 - b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - e) Estimated amount of the discharge;

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

- f) Location or address of the discharge;
 - g) Source and cause of the discharge;
 - h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - i) Description of area affected by the discharge, including name of water body affected, if any; and
 - j) Other persons or agencies contacted.
2. Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report.

[62-620.610(20)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX. 17., 18. and 19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX. 20 of this permit. *[62-620.610(21)]*

22. Bypass Provisions.

- a. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 - 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - 3. The permittee submitted notices as required under Permit Condition IX. 22. b. of this permit.
- b. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX. 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- c. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX. 22. a. 1. through 3. of this permit.
- d. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX. 22. a. through c. of this permit.

[62-620.610(22)]

23. Upset Provisions

- a. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 - 1. An upset occurred and that the permittee can identify the cause(s) of the upset;

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

2. The permitted facility was at the time being properly operated;
 3. The permittee submitted notice of the upset as required in Permit Condition IX. 20. of this permit; and
 4. The permittee complied with any remedial measures required under Permit Condition IX. 5. of this permit.
- b. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- c. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

X. Injection Wells:

1. General Criteria

- (a) The terms, conditions, requirements, limitations and restrictions set forth in this permit are "permit conditions" and are binding and enforceable pursuant to section 403.141, F.S.
- (b) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action.
- (c) As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
- (d) This permit conveys no title to land, water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (e) This permit does not relieve the permittee from liability for harm to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefrom; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
- (f) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, or are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (g) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
1. Have access to and copy any records that must be kept under conditions of this permit;
 2. Inspect the facility, equipment, practices, or operations regulated or required under this permit; and
 3. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time will depend on the nature of the concern being investigated.

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

(h) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

1. A description of and cause of noncompliance; and
2. The period of noncompliance, including dates and times; or, if not corrected the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent the recurrence of the noncompliance. The permittee shall be responsible for any and all damages, which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

(i) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

(j) The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

(k) This permit is transferable only upon Department approval in accordance with rules 62-4.120 and 62-528.350, F.A.C. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.

(l) This permit or a copy thereof shall be kept at the work site of the permitted activity.

(m) The permittee shall comply with the following;

1. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records shall be extended automatically unless the Department determines that the records are no longer required.
2. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
3. Records of monitoring information shall include:
 - a. the date, exact place, and time of sampling or measurements;
 - b. the person responsible for performing the sampling or measurements;
 - c. the date's analyses were performed;
 - d. the person responsible for performing the analyses;
 - e. the analytical techniques or methods used;
 - f. the results of such analyses.
4. The permittee shall furnish to the Department, within the time requested in writing, any information which the Department requests to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit.
5. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

(n) All applications, reports, or information required by the Department shall be certified as being true, accurate, and complete.

(o) Reports of compliance or noncompliance with, or any progress reports on, requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each scheduled date.

(p) Any permit noncompliance constitutes a violation of the Safe Drinking Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050

PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

(q) It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

(r) The permittee shall take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit.

(s) This permit may be modified, revoked and reissued, or terminated for cause, as provided in 40 C.F.R. sections 144.39(a), 144.40(a), and 144.41 (1998). The filing of a request by the permittee for a permit modification, revocation or reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

(t) The permittee shall give advance notice to the Department of any planned changes in the permitted facility or injection activity which may result in noncompliance with permit requirements.

(u) The permittee shall report any noncompliance which may endanger health or the environment including:

1. Any monitoring or other information which indicates that any contaminant may cause an endangerment to an underground source of drinking water; adjacent surface waters, or
2. Any noncompliance with a permit condition or malfunction of the injection system which may cause fluid migration into or between underground sources of drinking water. Any noncompliance with a permit condition or malfunction of the injection system which may cause migration of untreated or partially treated fluids into ground waters or adjacent surface waters of the State. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause, the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

(v) Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures.

(w) No underground injection is allowed that causes or allows movement of fluid into an underground source of drinking water if such fluid movement may cause a violation of any primary drinking water standard or may otherwise adversely affect the health of persons and or cause an exceedance of the minimum criteria for ground or surface waters of the State..

2. Signatories and Certification Requirements

1. All reports and other submittals required to comply with this permit shall be signed by a person authorized under Rules 62-528.340(1) or (2), F.A.C.
2. In accordance with Rule 62-528.340(4), F.A.C., all reports shall contain the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based upon my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

3. In the event a well must be plugged or abandoned, the permittee shall obtain a permit from the Department as required by Sections 62-528.625 and 62-528.645, F.A.C.
4. The permittee shall notify the Department and obtain approval prior to any well work or modification.
5. The permittee is reminded of the necessity to comply with the pertinent regulations of any other regulatory agency, as well as any county, municipal, and federal regulations applicable to the project. These regulations may include, but are not limited to,

FACILITY: City of Marathon Area 6
PERMITTEE: City of Marathon
10045-55 Overseas Highway
Marathon, FL 33050


PERMIT NUMBER: FLA579033
PA FILE NUMBER: FLA579033-DW2P/NP

those of the Federal Emergency Management Agency in implementing flood control measures. This permit should not be construed to imply compliance with the rules and regulations of other regulatory agencies.

Note: In the event of an emergency the permittee shall contact the Department by calling (800) 320-0519. The permittee shall call (239) 332-6975 during regular business hours.

Executed in Fort Myers, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management